Appendix E: Impressed Current 60 Day Inspection Form

FACILITY NAME/UST #:_____

AMP RANGE RECOMMENDED:_____

VOLTAGE RANGE RECOMMENDED:_____

Date	Your Name	Voltage Reading	Amp Reading	Is your system operating within the recommended Amp and Voltage Range? (Yes/No)

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- **KEEP THIS RECORD FOR AT LEAST 3 YEARS BEYOND THE OPERATIONAL LIFE OF THE FACILITY**